



**MYSRURU CITY CORPORATION
VANIVILASA WATER WORKS**

Laboratory Address:-Vanivilasa water works Analysis Laboratory, Mysuru City Corporation. Mysuru

ನೀರಿನ ಮಾದರಿಗಳ ವಿಶ್ಲೇಷಣಾ ವರದಿ ದಿನಾಂಕ: 09.04.2024

Sl no	Ward no	Sample Location	Residual chlorine	Turbidity	TDS	Conductivity	pH	Total alkalinity	Total Hardness	Calcium	Chloride	Fluoride	Bacteriological Examination Presumptive Coliform Test	
		IS 10500-2012	- PPM	5.0 NTU	<500 mg/l	Micro/mhos/cm	6.5-8.5	< 200 mg/l	< 200 mg/l	< 75 mg/l	< 250 mg/l	1.0-1.5 mg/l	0/100ml	Result
1	21	ಜಿ.ಎಸ್.ಎಸ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್.ಎಸ್ ಜಿ ಸಿ ಕ್ಯಾಂಪಸ್ 1ನೇ ಫ್ಲೋರ್	RO	0.3	66	133	7.75	52	42	32	14	0.11	0/100ml	ತೃಪ್ತಿಕರವಾಗಿದೆ
2	21	ಜಿ.ಎಸ್.ಎಸ್ ಪಬ್ಲಿಕ್ ಸ್ಕೂಲ್.ಎಸ್ ಜಿ ಸಿ ಕ್ಯಾಂಪಸ್ 1ನೇ ಫ್ಲೋರ್	0.2	0.2	113	226	8.09	90	86	44	23	0.15	0/100ml	ತೃಪ್ತಿಕರವಾಗಿದೆ

Chemist
VVWW.MCC Mysuru

Assistant Engineer
VVWW.MCC Mysuru

Assistant Executive Engineer
VVWW.MCC Mysuru